

School Name	Test Date (dd-mm-yyy)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation ID	Mitigation Description
Bamfield Community School	22-04-2024	First Draw	CF	Secondary Classroom	0.0029	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	CF	Secondary Classroom	0.0003	No	NA	FALSE
Bamfield Community School	22-04-2024	First Draw	WC	118- Boys Washroom	0.0011	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	WC	118- Boys Washroom	0.0003	No	NA	FALSE
Bamfield Community School	22-04-2024	First Draw	OT	Staff Lounge	0.0011	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	OT	Staff Lounge	0.0003	No	NA	FALSE
Bamfield Community School	22-04-2024	First Draw	WC	Washroom by Admin Hall	0.0015	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	WC	Washroom by Admin Hall	0.0003	No	NA	FALSE
Bamfield Community School	22-04-2024	First Draw	KC	103- Kitchen	0.0015	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	KC	103- Kitchen	0.0003	No	NA	FALSE
Bamfield Community School	22-04-2024	First Draw	WC	104- Girls Washroom	0.0011	No	NA	FALSE
Bamfield Community School	22-04-2024	Flushed	WC	104- Girls Washroom	0.0003	No	NA	FALSE
					-		-	