

School Name	Test Date (dd-mm-yyyy)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation ID	Mitigation Description
Maquina Elementary School	20-08-2023	First Draw	CF	Std 2 Janitor	0.0014	No	NA	FALSE
Maquina Elementary School	20-08-2023	Flushed	CF	Std 2 Janitor	0.0008	No	NA	FALSE
Maquina Elementary School	20-08-2023	First Draw	CF	Std 2 Work Area	0.0088	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	Flushed	CF	Std 2 Work Area	0.0015	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 2 classroom	0.0160	Yes	2A	
Maquina Elementary School	20-08-2023	Flushed	CF	Std 2 classroom	0.0027	No	2A	
Maquina Elementary School	20-08-2023	First Draw	CF	Std 1 in class room	0.0078	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	Flushed	CF	Std 1 in class room	0.0015	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 1 washroom next to janitor	0.0060	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	Flushed	CF	Std 1 washroom next to janitor	0.001	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	First Draw	WC	Std 1 boys washroom	0.0005	No	NA	FALSE
Maquina Elementary School	20-08-2023	Flushed	WC	Std 1 boys washroom	0.0005	No	NA	FALSE
Maquina Elementary School	20-08-2023	First Draw	WC	Std 1 washroom	0.0017	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	Flushed	WC	Std 1 washroom	0.0198	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 1 staff room	0.0008	No	NA	FALSE
Maquina Elementary School	20-08-2023	Flushed	CF	Std 1 staff room	0.0008	No	NA	FALSE
Maquina Elementary School	20-08-2023	First Draw	CF	Std 1 classroom	0.0008	No	NA	FALSE
Maquina Elementary School	20-08-2023	Flushed	CF	Std 1 classroom	0.0003	No	NA	FALSE
Maquina Elementary School	20-08-2023	First Draw	CF	Std 3 classroom	0.0058	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	Flushed	CF	Std 3 classroom	0.0058	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 3 classroom	0.0118	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	Flushed	CF	Std 3 classroom	0.0060	Yes	4F	Install a NSF-302 certified filter if the water point is essential and the source of lead is difficult to replace or could not be located and corrected. Repeat after corrective work. Inform management, regional public health office, and water supplier. Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 3 classroom	0.0025	No	NA	FALSE
Maquina Elementary School	20-08-2023	Flushed	CF	Std 3 classroom	0.002	No	NA	FALSE
Maquina Elementary School	20-08-2023	First Draw	WC	Std 3 girls washroom	0.006	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	Flushed	WC	Std 3 girls washroom	0.0027	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Repeat fixture following replacement.
Maquina Elementary School	20-08-2023	First Draw	CF	Std 1 janitor	0.0030	No	NA	FALSE