

School Name	Test Date (dd-mm-yyy)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation ID	Mitigation Description
Tsuma-as Elementary School	15-04-2024	First Draw	DW	Main floorfountain	0.0008	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	DW	Main floorfountain	0.0008	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Library	0.0012	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Library	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	OT	Staff Room	0.0005	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	OT	Staff Room	0.0012	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Home Economics	0.0007	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Home Economics	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	DW	Gym Fountain	0.0034	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	DW	Gym Fountain	0.0012	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Art room 1	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Art room 1	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Art room 2	0.0007	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Art room 2	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	WC	Boys washroom	0.0069	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Tsuma-as Elementary School	15-04-2024	Flushed	WC	Boys washroom	0.0005	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Sink Room 202	0.0017	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Sink Room 203	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	DW	Fountain near 203	0.0004	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	DW	Fountain near 203	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Room 204	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Room 204	0.0003	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	DW	Fountain near Girls washroom	0.0005	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	DW	Fountain near Girls washroom	0.0014	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	First Draw	CF	Classroom 208	0.001	No	NA	FALSE
Tsuma-as Elementary School	15-04-2024	Flushed	CF	Classroom 208	0.0003	No	NA	FALSE
					-	-	-	-