

School Name	Test Date (dd-mm-yyy)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation ID	Mitigation Description
Ucluelet Elementary School	19-04-2024	First Draw	CF	112- New Kindergarten	0.0015	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	CF	112- New Kindergarten	0.001	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	First Draw	KC	110.1Kitchen	0.0003	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	KC	110.1Kitchen	0.0003	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	First Draw	WC	117-Washroom	0.0145	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Elementary School	19-04-2024	Flushed	WC	117-Washroom	0.0015	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Elementary School	19-04-2024	First Draw	WC	128- Girls Washroom	0.0015	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	WC	128-Girls Washroom	0.001	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	First Draw	CF	133- Classroom	0.0016	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	CF	133- Classroom	0.0007	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	First Draw	WC	209- Washroom	0.0064	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Elementary School	19-04-2024	Flushed	WC	209- Washroom	0.0009	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Elementary School	19-04-2024	First Draw	CF	204- Classroom	0.0019	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	CF	204- Classroom	0.0003	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	First Draw	OT	106- Office	0.0022	No	NA	FALSE
Ucluelet Elementary School	19-04-2024	Flushed	OT	106- Office	0.0006	No	NA	FALSE
						-		-