

School Name	Test Date (dd-mm-yyy)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation ID	Mitigation Description
Ucluelet Secondary School	19-04-2024	First Draw	BF	E114- Girls WC	0.0031	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	BF	E114- Girls WC	0.0004	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	BF	E11- Boys WC	0.0098	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	Flushed	BF	E11- Boys WC	0.0038	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	First Draw	BF	E103- Girls Locker Room	0.0125	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	Flushed	BF	E103- Girls Locker Room	0.0038	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	First Draw	BF	112- WC	0.0024	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	BF	112- WC	0.0003	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	KC	122- Servery	0.014	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	Flushed	KC	122- Servery	0.0003	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	First Draw	WC	120-WC	0.01	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	Flushed	WC	120-WC	0.003	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	First Draw	OT	129-Office	0.0024	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	OT	129-Office	0.0003	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	OT	147- Staff Room	0.0036	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	OT	147- Staff Room	0.0006	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	BF	144- WC	0.0024	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	BF	144- WC	0.001	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	BF	168-WC's	0.0011	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	Flushed	BF	168-WC's	0.0008	No	NA	FALSE
Ucluelet Secondary School	19-04-2024	First Draw	CF	155 Science Classrooms	0.0098	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Ucluelet Secondary School	19-04-2024	Flushed	CF	156 Science Classrooms	0.0007	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
						-		-